



# Compliance Statement

## Screened Category 6<sub>A</sub> ISO/IEC, EN & ANSI/TIA Communication Cable

**GIGAMEDIA a brand of CONECTIS**  
**P/N GGM C6AFF4PFRxx**


**Category 6<sub>A</sub> Individual Foil and Overall Foil Screen**  
**100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Fire Retardant, LSFRHF, Copper Cable**

**CONECTIS**  
**CRT N°4, 312 Rue des Hauts de Sainghin**  
**59811 Lesquin, France**


***Compliance Statement No. 115966D***

*This Screened ISO/IEC, EN & ANSI/TIA, Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6<sub>A</sub> performance requirements of edition 2.2 of ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2011, ANSI/TIA Generic Cabling Standard 568-C.2, 2<sup>nd</sup> edition IEC Cable Standard 61156-5, incl. amendment 1 and requirements of CENELEC Cable Standard EN 50288-10-1:2012. Fire retardancy is verified according to IEC 60332-3-24 (Cat. C), IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 7. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 13<sup>th</sup> December 2017

  
Ole Lambertsen  
Test Responsible

Hoersholm, 13<sup>th</sup> December 2017

  
Jens Rytter Petersen  
General Manager